

Certificate of Conformity

Registered No.:

COC PVP03019/22B-02

File reference
PVP03019/22B-04

Test report No.
TRPVP03019/22B/04

Date of issue
2022-06-21

On the basis of the tests undertaken, the samples of the below product(s) have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out:

Applicant: Xiamen Kehua Digital Energy Tech Co., Ltd
Room 208-38, Hengye Building, No. 100 Xiangxing Road, Torch High-tech Zone (Xiang'an) Industrial Zone, Xiamen, China.

Manufacturer: Xiamen Kehua Digital Energy Tech Co., Ltd
Room 208-38, Hengye Building, No. 100 Xiangxing Road, Torch High-tech Zone (Xiang'an) Industrial Zone, Xiamen, China.

Factory: ZHANGZHOU KEHUA ELECTRIC TECHNOLOGY CO., LTD
NO.11, JINXING ROAD, XIANGCHENG DISTRICT, ZHANGZHOU CITY, FUJIAN PROVINCE, CHINA

Product: PV Grid-tied Inverter

Type designation: SPI8K-B X2, SPI10K-B X2, SPI12K-B X2, SPI15K-B X2, SPI17K-B X2, SPI20K-B X2, SPI23K-B X2, SPI25K-B X2, SPI25K-B X2P
Three-phase, Firmware version: V3

Certification program: BOS-P-01 Rev. 00

Certification fundamental(s): IEC 61727:2004, IEC 62116:2014
See test report for detailed information.

This document is based on the evaluation of the samples of the above mentioned product(s). It does not imply an assessment of the mass-production of the product(s), and it does not permit the use of a TÜV NORD mark. The holder of this document may use it in connection with the related test report(s).



Renewable Energy

BOS-T-015 COC



中国认可
产品

PRODUCT
CNAS C183-P

Page 1 of 1

TÜV NORD (HANGZHOU) CO., LTD.
Member of TÜV NORD Group
Tel: +86-571-85386989
Fax: +86-571-85386986
www.tuv-nord.com/cn
P.R. China

Version 1.3